

ADDENDUM – 1

October 11, 2024

PAWTUCKET HOUSING AUTHORITY Galego Court Stair Tower Repairs

Project Site:

483 Weeden Street, Pawtucket, RI 02860

The following changes, modifications, and clarifications are hereby made to the plans and specifications for the above referenced project.

- Item 1: The Contractor shall assume a 1,500 PSF soil bearing capacity for the base bid for all stair towers and shall refine their design after the geotechnical explorations.
- Item 2: In the case of inclement weather, the Engineer and the successful bidder shall coordinate to reasonably increase the length of the project from 120 calendar days.

We have attached the following document as part of this Addendum:

1. Pre-Bid Sign-in Sheet

Date: **October 7, 2024**
 RE: **Pre-Bid Sign-in Sheet**
 Project Title: **Galego Ct Stair Tower Repairs**
 Project Number: **18462**

PRE-BID SIGN IN SHEET:

NO.	COMPANY NAME	CONTACT PERSON	PHONE	EMAIL
1	Dubon masonry	Chris Reynolds	401-500-5062	ESTIMATING @ DUBON MASONRY, INC
2	FREEMONT GENERAL	KEN BOSTIC	401 744-0094	KhbPRES@GMAIL.COM
3	REDOAK REMODELING	BILL CONLAN	401-829-7299	REDOAKREMODELING@COX.NET
4	Handwritten Pawtucket Housing	Alicia Stipa	401-265-0773	astipa@pawthousing.org
5	Verdantas	Evan Boltrushch	401-649-1121	erboltrushch@verdantas.com
6	W H Peppers	Bill Pepp	440-4828	bill@whpeppers.com
7				
8				
9				
10				